

RB Tele No. 3/2015

(भारत सरकार) GOVERNMENT OF INDIA  
(रेल मंत्रालय) MINISTRY OF RAILWAYS  
(रेलवे बोर्ड) (RAILWAY BOARD)

No. 2011/Tele/6(3)/11/Pt.

New Delhi,  
Dated: 18.2.15

✓ The Chairman & Managing Director,  
RailTel Corporation of India Ltd.  
Plot No. 143, Institutional Area,  
Opp. Goldsouk, Sector-44,  
Gurgaon - 122003.


TELECOM CIRCULAR No. 3/2015

Sub: Provision of DC Power Supply for RCIL equipments from  
Railways Short Haul PoPs.

Ref: RCIL/2005/DNM/Rly/475/pt. dated 18.11.2014.

RCIL vide its letter referred above have indicated the requirement of DC Power Supply at way side stations (short haul Point of Presence) to extend services in the rural part of the country and play a lead role in the Digital India Initiative of the Government.

Board(ML) has approved provision of DC Power supply (6/12/24/48 Volts as required) with total maximum consumption upto 200 Watts from Railways' existing Telecom power supply at way side stations, free of cost. RCIL to draw the power supply from the battery bank with adequate protection.

  
18.2.15  
(शोभन चौधरी)

Executive Director (Tele Dev)  
E-mail: edtd@rb.railnet.gov.in  
FAX 030-44198/011-23304198

C/- All CSTE's for kind information and necessary action.